



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Jalkal Mayapur, Haridwar
 Ph (O): 0134-226360, E-mail: eeujshrd@yahoo.com



TC-12836

TEST REPORT

Name and Address of Organization/ Customer	The Blossoms Global School, Sehdevpur Road, Near Patanjali yogpeeth,		
Test Report ID	255/UJS/DLWQTM/2024-25	Reporting Date	24/03/2025
ULR No.	TC128362400000095F	Sample Location	Blossoms Global School, Sehdevpur Road, Near Patanjali yogpeeth
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTM/UJS/2025-255		
Date of Start of Analysis:	19/03/2025		
Date of End of Analysis:	24/03 /2025		
Date and Time of Sample Received:	19/03/2025 & 02:15 pm		

SN	Parameters	Test Method	Result	Acceptable Limit As per (IS10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
1.	pH at 25°C	IS 3025 (Part 11), 2022,	7.58	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180°C mg/L, Max	IS 3025 (Part 16), 2023	382	500	2000
3.	Turbidity, NTU, Max	IS 3025 (Part 10), 2023	0.93	1	5
4.	Total Alkalinity (as CaCO ₃), mg/L, Max	IS 3025 (Part 23), 2023	194	200	600
5.	Total Hardness (as CaCO ₃), mg/L, Max	IS 3025 (Part 21), 2009	250	200	600
6.	Calcium as Ca, mg/l	IS 3025 (Part 40), 2019	60.8	75	200
7.	Chloride, mg/L, Max	IS 3025 (Part 32), 2019	14	250	1000
8.	Magnesium as Mg, mg/l	APHA 24 th Ed -3500-Mg Method B:2023 (Calculation Method)	23.81	30	100
9.	Colour, Hazen, Max	IS 3025 (Part 4): 2021	1	5	15
10.	Odour	IS 3025 (Part 5) : 2018	Agreeable	Agreeable	Agreeable

Note:

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

District Water Quality Testing Monitoring
 Lab.
 Uttarakhand Jal Sansthan, Haridwar



Aug 1
 (Er. Anjali Palariya)

Review and Authorized By
 Authorized Signatory,
 District Water Quality Testing Monitoring
 Laboratory,
 Uttarakhand Jal Sansthan, Haridwar



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Jalkal Mayapur, Haridwar
 Ph (O): 0134-226360, E-mail: eeujshrd@yahoo.com

TEST REPORT

Name and Address of Organization/ Customer	The Blossoms Global School, Sehdevpur Road, Near Patanjali yogpeeth,		
Test Report ID	255/UJS/DLWQTM/2024-25	Reporting Date	24/03/2025
		Sample Location	Blossoms Global School Sehdevpur Road, Near Patanjali yogpeeth
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTM/2025-255		
Date of Start of Analysis:	19/03/2025		
Date of End of Analysis:	24/03/2025		
Date and Time of Sample Received:	19/03/2025 & 02:15 pm		

SN	Parameters	Test Method	Results	Acceptable Limit As per (IS 10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
1.	Residual Free Chlorine, mg/L, Min	APHA 23rd Ed.-4500- CI-G	Absent	0.2	1.0
2	Total Coliform, MPN/ 100ml	APHA 23rd Ed.-9223-B	Absent	Absent	Absent
3	E. coli, MPN/ 100ml	APHA 23rd Ed.-9223-B	Absent	Absent	Absent

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

19/03/25
 District Level Water Quality Testing Monitoring
 Laboratory, Uttarakhand Jal Sansthan, Haridwar

19/03/25
 (Er. Anjali Palariya)

Review and Authorized By
 Authorized Signatory,
 District Water Quality Testing Monitoring
 Laboratory,
 Uttarakhand Jal Sansthan, Haridwar

